

Adult Foster Home
Carbon Monoxide/Smoke Alarm/Extinguisher Tracker
 411-050-0720(8)(b) and 411-050-0720(7)(a) & (c)

Year:	Smoke Detector Test			Carbon Monoxide Test			Fire Extinguisher		
	Date	Initial	Notes	Date	Initial	Notes	Date	Initial	Notes
January									
February									
March									
April									
May									
June									
July									
August									
September									
October									
November									
December									

Year:	Smoke Detector Test			Carbon Monoxide Test			Fire Extinguisher		
	Date	Initial	Notes	Date	Initial	Notes	Date	Initial	Notes
January									
February									
March									
April									
May									
June									
July									
August									
September									
October									
November									
December									

411-050-0720(8)(b) CARBON MONOXIDE AND SMOKE ALARMS. (b) The licensee or administrator must test all carbon monoxide alarms and smoke alarms in accordance with the manufacturer's instructions at least monthly (per NFPA 72). Testing must be documented in the facility records. The licensee or administrator must maintain carbon monoxide alarms, smoke alarms, and fire extinguishers in functional condition. If there are more than two violations in maintaining battery operated alarms in working condition, the Department may require the licensee to hard wire the alarms into the electrical system.

411-050-0720(7)(a) & (c) FIRE EXTINGUISHERS. At least one fire extinguisher with a minimum classification of 2-A:10-B:C must be mounted where they are easily visible and readily accessible for use on each floor, including basements. (a) Fire extinguishers shall be inspected by the licensee or designated staff at least once per calendar month. (c) Documentation of monthly and annual inspections for each fire extinguisher shall be maintained and made available upon request.